



Connecticut Specifications

<u>CTL 12</u>	ELA 8.3 SF/LF	Liquid storage to invert bottom 21.5 Gallons/LF
<u>CTL 18</u>	ELA 10.7 SF/LF	Liquid storage to invert bottom 37.6 Gallons/LF
<u>CTL 24</u>	ELA 13 SF/LF	Liquid storage to invert bottom 53.75 Gallons/LF
<u>CTL 48</u>	ELA 21.9 SF/LF	Liquid storage to invert bottom 118.4 Gallons/LF

Calculation for D.E.P. Systems

CTL 18 ELA 14.1 SF/LF

GoodFlow Solutions

23 Ryan Street • Stamford CT 06907
P (203) 869-2969 • F (203) 869-2977
info@goodflow.com • www.goodflow.com