



## Massachusetts Specifications

- One row of GoodFlow CTL 12 units when calculated in bed configuration receives an E.L.A. of 10.57 SF/LF after a 40% reduction. The GoodFlow chambers have been designed and constructed to utilize two distribution lines. • In trench configuration, the CTL 12 receives an E.L.A. of 7.24 SF/LF and the CTL 18 receives an E.L.A. of 8.91 SF/LF.
- GoodFlow chambers come in standard 8' long sections with 4' end sections available to allow the designer variable total system length options.
- GoodFlow systems are approved for New Construction & Remedial System Applications.
  - GoodFlow systems are exempt from minimum inlet spacing requirements.
- When installed in bed configuration, the system may be installed without distribution piping.
- The GoodFlow systems are exempt from written notice of alternative system prior to property transfer, need for a certified operator, need for an operation and maintenance contract with operator and deed notice.
- Only gravel less chamber system allowed in H2O loading applications In Massachusetts
- GoodFlow systems are exempt from pressure dosing and distribution piping on systems up to 5,000 GPM

---

### GoodFlow Solutions

23 Ryan Street • Stamford CT 06907  
P (203) 869-2969 • F (203) 869-2977  
info@goodflow.com • www.goodflow.com