



## Department of Health

**ANDREW M. CUOMO**  
Governor

**HOWARD A. ZUCKER, M.D., J.D.**  
Commissioner

**SALLY DRESLIN, M.S., R.N.**  
Executive Deputy Commissioner

September 8, 2016

Mr. Frank Currivan  
President  
Cur-Tech Systems  
23 Ryan Street  
Stamford, CT 06907

Re: Cur-Tech CTL12 and CTL18 Compliance  
Sand Filter Determination

Dear Mr. Currivan:

We received on June 7, 2016 your request and the supporting information for the Cur-Tech CTL12 and CTL18 Sand Filter systems to be classified pursuant to applicable requirements as described in Section 75-A.8 (c)(3)(iii) of Appendix 75 – A, “Wastewater Treatment Standards – Residential Onsite Systems.” This Department does not “approve” proprietary products. We will, however, review products as a courtesy to determine their compliance with the Appendix 75-A regulations.

The Cur-Tech systems each consist of a four (4) foot by eight (8) foot concrete chamber with an open bottom. Plastic fins composed of ABS are designed to fit into openings on both sides of the concrete chamber. The CTL12 system consists of a concrete chamber measuring 14” in height with plastic fins measuring 12” in height. The CTL18 system consists of a concrete chamber measuring 20” in height with plastic fins measuring 18” in height. Using these configurations, the criteria set forth in Section 75-A.8 (c)(3)(iii) is met and therefore the Cur-Tech CTL12 and CTL18 systems may be designed and installed in accordance with the requirements of that section. Please note that all other applicable design, installation, and site requirements of Appendix 75-A must be followed.

Onsite wastewater treatment systems (OWTS) and the use of proprietary products may also be subject to the conditions and requirements of local health departments, local code enforcement offices, watersheds, or the New York State Department of Environmental Conservation. Local standards may be more stringent than those included in Appendix 75-A.

This is in no way intended to be, nor should it be construed as, an endorsement of your product. Your product was provided a compliance determination review in accordance with this Department’s practices for product reviews, using Appendix 75-A as the applicable regulation.

Please feel free to contact me with any questions or concerns at (518) 402-7650 or via email at [Richard.maclelath@health.ny.gov](mailto:Richard.maclelath@health.ny.gov)

Sincerely,

A handwritten signature in cursive script, appearing to read "Dan MacElrath".

Dan MacElrath  
Public Health Engineer  
Bureau of Water Supply Protection

cc: K. Kenyon